# PRODUCT TYPE E8X

B

REFERENCE NUMBER: 3.5.0

L

E Gland designed for use with Armoured Cables

<

EXAMPLE PART NUMBERING: E8XBF/NP/20/050NPT

OPTIONS

о м

PLATING:

100-0000

### Double Compression Gland designed for use with Armoured Flat Cable

Ex d : Ex e : Ex nR : Ex ta : IP66 : IP68 : Class I Div 2 : AEx e : AEx ta

#### PART NUMBERS:

E 8 X B F

## S

PRODUCT DESCRIPTION "E8X" type glands are certified Flameproof Ex d, Increased Safety Ex e, Restricted Breathing Ex nR and Dust Protected Ex ta. They are suitable for use in Zone 1 and 2 for Gas Groups IIA, IIB and IIC and additionally for use in Zones 20, 21 and 22 for Dust Groups IIA, IIIB and IIC. Developed for flat cables, they provide controlled Ex d sealing and have been tested to IP66 and IP68 to 50 metres. The E8X version is designed to accommodate armoured cables, sealing on the inner and outer sheaths and also incorporates a detachable armour specific clamping system.

🤆 🔂 🎬 🦉 [H[ 🌆 🍙 🕑 🕑 🧾 🔛 😰 🤣

o 🔚 🚘 💌 💻 🐼 🏙 💳 📼

#### COMPLIANCE STANDARDS:

EN 60079-0, EN 60079-1, EN 60079-7, EN 60079-15, EN 60079-31	
IEC 60079-0, IEC 60079-1, IEC 60079-7, IEC 60079-31 & IEC 60529	
UL514B, UL1203, UL2225, UL50E, ANSI/UL 60079-0/7, ISA 60079-31	

	_	chana acoig										
	8	Silicone Sea	Is for flat cables	CERTIFICATION:	ATEX	ll 1D 2G Ex d IIC Gb / Ex e IIC Gb / Ex ta IIIC Da						
	x	Detachable	Clamping for Braid Armour			II 3G Ex nR IIC Gc						
	в	Brass (B) / S	Stainless Steel (S)		IECEx	Ex d IIC Gb / Ex e IIC Gb / Ex ta IIIC Da						
	F	Multiple Cer	tification		NEC - USA	Class I Zone 1 AEx e IIC Gb / Class II Zone 20 AEx ta IIIC Da						
	L	Locknut (ma	terial dictated by gland entry thread material)			Class II Division 1, Groups E, F & G						
	-					Class III, Enclosure Type 4X						
	н	Including IP	Washer, Nylon (N) - Fibre (V) - PTFE (H)		EAC	Exd IICU / Exe IIU / ExnR IIU						
	т	Including Ea	rth Tag		INMETRO - Brazil	Ex d IIC Gb / Ex e IIC Gb / Ex ta IIIC Da / Ex nR IIC Gc						
	s	Including Se	errated Washer		SAC - China	Ex d IIC / Ex e IIC						
		0			UKRAINE	Ex d IIC X / Ex e II X						
	1	Quantity per	KIL		CCoE - India	Petroleum Rules 2002 (PESO)						
	NP	Nickel Plate	d		ABS	Specified ABS Rules						
	20	Gland shell s	size		LLOYD'S	Enclosure Systems (Part 1B)						
050	NPT	1/2"NPT Ma	le Entry Thread		RMRS	Part XI of RS Rules for the classification & construction of sea-going ships (ed. 2014)						
OCKNUT Brass (ACBLN) / Stainless Steel (ACSLN)					ATEX	SIRA 01ATEX1270X & SIRA 09ATEX1221X						
					IECEx	IECEx SIR 05.0020X						
EARTH TAG Brass (ACBET) / Stainless Steel (ACSET)					NEC - USA	CSA 2627370						
P WASHERS Nylon (ACNSW) / Fibre (ACFSW) / PTFE (ACPSW)				CERTIFICATION No:	EAC	RU C-GB.F606.B.00098						
SERRATED WASHERS Stainless Steel (ACSSW)					SAC - China	NCC 13.2187 X						
					INMETRO - Brazil	NEPSI GYJ16.1398X						
P RATING:			IP66 & IP68 (50 metres - 7 Days), Type 4X		UKRAINE	UA.TR.047.C.0408-13 & 2937						
OPERATING TEMP:      Silicone Seals -60°C to +180°C					CCoE - India	PESO P365300/2 & P365300/6						
MATER	MATERIALS:		Brass or Stainless Steel		ABS	14-LD463991-1-PDA						
					LLOYD'S	10/00056(E1)						

CABLE GLAND SELECTION TABLE (ALL DIMENSIONS IN mm)

	Entry Thread Size		Metric Thread Length [B]	Cable Inner Sheath [C] Width Thickness			Cable Outer Sheath [D] Width Thickness				Armour	Nominal	Dimensions/Weight (Metric Versions)			
Gland Size	Size Metric NPT	Min		dth Max	Thick Min	Max	Min	dth Max	Min	kness Max	Acceptance Range	Protrusion Length [L]	Across Flats [A]	Across Corners	Weight Kgs (Metric)	
20S	M20 x 1.5	1/2" or 3/4"	16	6.3	11.7	4.0	7.0	7.9	11.7	4.5	7.0	0.10-0.30	63	30.0	33.0	0.212
20R	M20 x 1.5	1/2" or 3/4"	16	8.1	13.5	5.8	6.2	10.7	16.1	5.4	8.3	0.10-0.30	64	30.0	33.0	0.213
20	M20 x 1.5	1/2" or 3/4"	16	10.3	13.5	5.6	9.0	11.0	13.5	4.5	9.0	0.10-0.30	63	30.0	33.0	0.212

RMRS

14.02755.315

• Gland size does not necessarily equate to the entry thread size.

Electroless Nickel

- Dimensions (A) & (B) may differ for glands with non metric entry threads. Please refer to our "Thread Reference Tables" for specific dimensions.
- Assembly instructions must be read prior to installation and adhered to in full.
  Peppers supplies cable glands with parallel entry threads that conform to the flameproof threaded joint requirements of IEC/EN 60079-1 and other equivalent standards. They usually incorporate a thread run out according to the available machining techniques and will not have a full form thread for the entire length.

Peppers Cable Glands Limited will not be held responsible for clients' installations where this has not been taken into account.

- When selecting IP Washer material for use with glands, please be aware of the accessories temperature range to ensure they are suitable for the intended installation.
- Where approval in addition to ATEX, IECEx and CSA is required, this must be clearly requested at time of enquiry / order.

Peppers Cable Glands Ltd: www.cableglands.com | Email: sales@peppers.co.uk | Tel: +44 (0) 1276 64232

3.5.0